

Energy performance certificate (EPC)

16, Rosedale Avenue CONSETT DH8 0DZ	Energy rating	Valid until: 19 December 2028
	G	Certificate number: 9623-3012-0482-0690-9295

Property type	A1/A2 Retail and Financial/Professional services
Total floor area	41 square metres

Rules on letting this property

! You may not be able to let this property.


This property has an energy rating of G. The landlord cannot grant a tenancy to new or existing tenants, unless an exemption has been registered.

From 1 April 2023, landlords will not be allowed to continue letting a non-domestic property on an existing lease if that property has an energy rating of F or G.

Properties can be let if they have an energy rating from A+ to E. The [recommendation report](#) sets out changes you can make to improve the property's rating.

Energy rating and score

This property's energy rating is G.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

70 C

If typical of the existing stock

205 G

Breakdown of this property's energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	93.83
Primary energy use (kWh/m ² per year)	555

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/0960-0648-2429-3192-2096\)](/energy-certificate/0960-0648-2429-3192-2096).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Stephen Donaghy
Telephone	01207 524 823
Email	stephen@elvetconsultants.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/021018
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Elvet Construction Consultants
Employer address	Unit 5 The Greenhouse, Greencroft Industrial Estate, Annfield Plain, Durham, DH9 7XN
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	11 December 2018
Date of certificate	20 December 2018